

ThompsonRPM

THIS IS TO CERTIFY THAT THE:

JASH MAHR BANDSCREEN

WAS TESTED AT THE:

**NATIONAL SCREEN EVALUATION FACILITY
CHESTER LE STREET STW
NORTHUMBRIAN WATER**

JANUARY 2017

AVERAGE SCREENINGS CAPTURE RATIO = 89%

FOR FURTHER DETAILS REFER TO:

THOMPSON RPM REPORT REF- TRPM-REP311

Barry Thompson
Thompson RPM Ltd